


IEC IECEE CB SCHEME		Ref. Certif. No. SE-71083
IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC		
CB TEST CERTIFICATE		CERTIFICAT D'ESSAI OC
Product Produit	Circuit-breakers for overcurrent protection	
Name and address of the applicant Nom et adresse du demandeur	Gacia Electrical Appliance Co., Ltd. 545# Dongdajie Baitawang Industrial Zone, Beibaixiang, Wenzhou 325603, CHINA	
Name and address of the manufacturer Nom et adresse du fabricant	Same as above	
Name and address of the factory Nom et adresse de l'usine Note: When more than one factory, please report on page 2 Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page	Same as applicant	
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	U_e= 240V~(1P), 415V~(2P, 3P, 4P) I_n= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A; B- and C-Type I_{cs}= I_{cn}= 6000A	
Trademark (if any) Marque de fabrique (si elle existe)	GACIA	
Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur	-	
Model / Type Ref. Ref. De type	M60, M60H, SB6L, SB6H, SB6HS, SB6LC, SB6HC	
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page)	See page 2	
A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la	IEC 60898-1:2002+A1+A2	
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat	SH12080827-001, SH12080827-002, SH12080827-003, SH12080827-004	
This CB Test Certificate is issued by the National Certification Body Ce Certificat d'essai OC est établi par l'Organisme National de Certification		
Intertek Semko AB Box 1103 SE-164 22 Kista, Sweden Int +46 8 750 00 00 Date: 26 November 2012	Intertek Signature:  Bo Berglöf	

IEC IECEE CB SCHEME		Ref. Certif. No. SE-71083
Additional information (if necessary) Information complémentaire (si nécessaire)		
M60H is identical to M60 except a groove on each input terminal. SB6L, SB6H, SB6HS are identical to M60H. SB6LC, SB6HC are identical to M60H except hyaline front cover.		
Date: 26 November 2012	Signature: 	