

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

Schotman Elektro B.V.
Weverstraat 4 9403 VJ Assen
Netherlands

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

1P+N, 50 / 60 Hz
Ue: 230 / 240 Vac
In: 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40 A, type B and C
Ics = Icn = Icn1 = 6 kA, the grid distance "a": 50 mm

Trademark / Brand (if any)

SEP

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

INS18

Additional information (if necessary may also be reported on page 2)

Energy limiting class 3 according to EN 60898-1:2019.
This certificate is based on CB certificate NL-84657 issued on 2022-11-29.☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

3326925.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-01-09

Signature: H.L. Schendstok

A handwritten signature in blue ink, appearing to read 'H.L. Schendstok', is written over the printed name.