

# ATTESTATION OF CONFORMITY

Issued to: Schotman Elektro B.V.  
Weverstraat 4 9403 VJ Assen, The Netherlands

For the product: Circuit breakers for overcurrent protection

Trade name: SEP

Type/Model: INS18

Ratings: 1P+N, 50 / 60 Hz  
Ue: 230 / 240 Vac  
In: 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40 A, type B and C  
Ics = Icn = Icn1 = 6 kA, the grid distance "a": 50 mm  
Energy limiting class 3

Manufactured by:

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015, IEC 60898-1:2015/A1:2019

Additional information: This attestation is based on 3323471.01A issued on 2022-12-07.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a report no. 3326925.50 issued on 2022-12-19.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 12 January 2022      Number: 3326925.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

