

ATTESTATION OF CONFORMITY

Issued to: Schotman Elektro B.V.
Weverstraat 4 9403 VJ Assen, The Netherlands


For the product: Circuit breakers for overcurrent protection

Trade name: SEP

Type/Model: INS18

Ratings: 1P+N, 50 / 60 Hz
Ue: 230 / 240 Vac
In: 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40 A, type B and C
Ics = Icn = Icn1 = 6 kA, the grid distance "a": 50 mm
Energy limiting class 3

Manufactured by:



Requirements: BS EN 60898-1:2019

Additional information: This attestation is based on 3323471.02A issued on 2022-12-07.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a report no. 3326925.50 issued on 2022-12-19.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

Wenzhou, Zhejiang, 12 January 2023

Number: 3326925.02A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J. Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing Services (Zhejiang) Co., Ltd
No. 5. Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, 325603 Zhejiang, China
T www.dekra-product-safety.com

UK
CA