

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

Schotman Elektro B.V.
Weverstraat 4 9403 VJ Assen
Netherlands

Name and address of the manufacturer

[Redacted]

Name and address of the factory

[Redacted]

Note: When more than one factory, please report on page 2 Additional information on page 2

Ratings and principal characteristics

1P, 2P, 3P, 4P, Ui: 690 V, Uimp: 8 kV, 50 / 60 Hz
Ue: 230 / 400 Vac, 240 / 415 Vac for 1P, 400 Vac, 415 Vac for 2P, 3P, 4P
Ie: 25, 40, 63, 80, 100, 125 A of AC-21A/B, AC-22A/B, AC-23A/B,
160 A of AC-21A/B, AC-22A/B
Icw: 2000 A / 1 s, Icm: 1500 A
Terminal connection:
Minimum conductor: 1,5 mm² of solid, stranded or flexible
Maximum conductor: 50 mm² of flexible, 70 mm² of stranded

Trademark / Brand (if any)

SEP

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HS1

Additional information (if necessary may also be reported on page 2)

This certificate is based on the CB certificate NL-84513 issued on 2022-11-28.

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

3324684.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-01-09

Signature: H.L. Schendstok