

ATTESTATION OF CONFORMITY

Issued to: Schotman Elektro B.V.
Weverstraat 4, 9403 VJ Assen, The Netherlands

For the product: Switch-disconnectors

Trade name: SEP

Type/Model: HS1

Ratings: 1P, 2P, 3P, 4P, Ui: 690 V, Uimp: 8 kV, 50 / 60 Hz
Ue: 230 / 400 Vac, 240 / 415 Vac for 1P, 400 Vac, 415 Vac for 2P, 3P, 4P
Ie: 25, 40, 63, 80, 100, 125 A of AC-21A/B, AC-22A/B, AC-23A/B,
160 A of AC-21A/B, AC-22A/B
Icw: 2000 A / 1 s, Icm: 1500 A
Terminal connection:
Minimum conductor: 1,5 mm² of solid, stranded or flexible
Maximum conductor: 50 mm² of flexible, 70 mm² of stranded

Manufactured by:



Requirements: BS EN IEC 60947-3:2021

Remark: This attestation is based on 3324682.02A issued on 2022-12-07.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 3324684.50 issued on 2022-12-15.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

Wenzhou, Zhejiang, 13 January 2023 Number: 3324684.02A

DEKRA Testing Services (Zhejiang) Co., Ltd

J. Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed